



Address	Map and Lot	Permit Number	Contractor Name	Inspector
9 Minute Man Ln	50-142	6295	Iovino Excavating	msprague
Date	Material	Depth of Cover	Amount	
8/25/2015	6x6 Fern co.	6 ft	1-Connect to existing stub	
	6" PVC Pipe - SDR 35		55 ft to 45° Bend	
	6" PVC 45° Bend		1	
	6" PVC Pipe - SDR 35		10 ft to Clean Out	
Type of work completed				

New 6" PVC sewer service installed to new house, connection to existing stub at main.