



Address	Map and Lot	Permit Number	Contractor Name	Inspector
30 Patterson	59-102	6374	Susi & Mascio	msprague
Date	Material	Depth of Cover	Amount	
9/3/2015	6x6 AC to PVC Fern Co	4 ft	1-Connect to existing stub	
	6" PVC Pipe - SDR 35		31.4 ft	
	6" PVC Clean out		1	
	6" PVC Pipe - SDR 35		8.7 ft	
	6 in to 4 in Fernco		1	
Type of work completed				

New 6" PVC sewer service installed to new house, connection to existing stub.