



Address	Map and Lot	Permit Number	Contractor Name	Inspector
26 Slocum	40-47	5804	McLaughlin, James M. Inc.	dpavlik
Date	Material	Depth of Cover	Amount	
12/26/2014	6x6 AC to PVC Fern Co	6.5 ft	1-Connect to existing AC Line	
	6" PVC Pipe - SDR 35		30 ft to Clean out	
	PVC Clean Out	8 ft	1	
	22 Degree Bend	8 ft	1	
Type of work completed				
New 6" PVC sewer service installed to new house, connection to existing line.				