



| Address | Map and Lot | Permit Number | Contractor Name | Inspector |
|-------------------------------|---|----------------|--|-----------|
| 5 Thoreau Rd | 69-12 | 6071 | S&T Frotton, Inc. | msprague |
| Date | Material | Depth of Cover | Amount | |
| 4/17/2014 | 6x6 VC to PVC Fern Co 6" PVC Pipe - SDR 35 | 5 ft | 1-Connect to existing stub 77 ft ft to CO | |
| Type of work completed | | | | |

New 6" PVC sewer service installed to new house, connection to existing stub.