



Address	Map and Lot	Permit Number	Contractor Name	Inspector
18 Walnut St	4-17	5887	Caccavaro Const Inc	dpavlik msprague
Date	Material	Depth of Cover	Amount	
9/18/2014	6x6 AC to PVC Fern Co	3.4 ft	1-Connect to existing stub	
	6" PVC Pipe - SDR 35		34 ft to 22 degree bend	
	22 degree PVC Bend		1	
	PVC Clean Out		1	
	6" PVC Pipe - SDR 35	8 ft	6 ft to HSE	
Type of work completed				

New 6" PVC sewer service installed to new house, connection to existing stub.