



Address	Map and Lot	Permit Number	Contractor Name	Inspector
455 Waltham St	32-5A	6195	Iovino Excavating	msprague
Date	Material	Depth of Cover	Amount	
6/25/2015	6x6 PVC to AC Fern co	4 ft	1-Connect to existing stub	
	6" PVC Pipe - SDR 35		68.5 ft	
	22° Bend		1	
	6" PVC Pipe - SDR 35		40 ft	
	45° Bend		1	
Type of work completed				
New 6" PVC sewer service installed to new house, connection to main.				