



| Address                       | Map and Lot  | Permit Number  | Contractor Name  | Inspector |
|-------------------------------|--|----------------|--|-----------|
| 273 Woburn St                 | 46-118   | 6069           | McLaughlin, James M. Inc.  | msprague  |
| Date                          | Material   | Depth of Cover | Amount   |           |
| 3/19/2015                     | 6x6 Fern Co<br>6" PVC Pipe - SDR 35<br>PVC Clean out | 8 ft           | 1-Connect to existing stub<br>63.7 ft to Clean out<br>12 ft to HSE |           |
| <b>Type of work completed</b> |  |                |  |           |

New 6" PVC sewer service installed to new house, connection to existing stub at main.