

| Address  | Map and Lot                   | Permit Number  | Contractor Name   | Inspector |
|--|-------------------------------|----------------|-------------------|-----------|
| 85 Reed St   | 72-498                        | 6064           | Taylor Excavation | msprague  |
|  |                               |                |                   |           |
| Date   | Material                      | Depth of Cover | Amount            |           |
| 1/23/2015  | 3/4" Copper type "k"          | 5.5 ft         | 1 ft              |           |
|  | 3/4" to 1" fitting            | 5.5 ft         | 1                 |           |
|  | 1" Copper type "k"            | 5.5 ft         | 1 ft              |           |
|  | 1" Curb Valve and Buffalo Box | 5.5 ft         | 1                 |           |
|  | 1" Copper type "k"            | 7 ft           | 29 ft to HSE      |           |
|  |                               |                |                   |           |
|  |                               |                |                   |           |
|  |                               |                |                   |           |
| Type of work completed   |                               |                |                   |           |
| Nov. 1" water consider to have a frame cumb step. Nov. have an let old have a repeated |                               |                |                   |           |

New 1" water service to house from curb stop. New house on lot old house removed.

Printed Date: 1/29/2015