

Address	Map and Lot	Permit Number	Contractor Name	Inspector
18 Walnut St	4-17	5887	Caccavaro Const Inc	dpavlik
				msprague
Date	Material	Depth of Cover	Amount	
9/18/2014	1" Copper type "k"	9 ft at HSE	60 ft	
	1" Curb Valve and Buffalo Box	4 ft		
				1
Type of work completed				

New 1" water service to house from curb stop. New house on lot old house removed.